



ATMOSPHERIC TESTING & MONITORING

Corresponding permit no.

1 of 2



LOCATION

Describe, draw or list atmospheric testing locations associated with activity

TESTING/MONITORING REQUIREMENTS

The equipment to be used must be calibrated as per the manufacturers requirements, and bump tested at least daily before work commences. The worksite and surrounding areas noted above are to be tested at the following frequency.

Frequency (tick as applicable)	Once before the start of work	Continuous monitoring during work	After Fuel Delivery	At a specified frequency		
Acceptable levels of Gas/Vapour/Asphyxiant:	Max	Oxygen % Vol Min	Flammables % of the LEL	H2S ppm	CO ppm	Other (Specify)

Name/s of Authorised Gas Tester (AGT)

EQUIPMENT VALIDATION

Date	Make/Model	Gas Test Unit No.	Calibration Date	Bump Test Time	AGT signature

