



ATMOSPHERIC TESTING & MONITORING

Corresponding permit no.

1 of 2



LOCATION

Describe, draw or list atmospheric testing locations associated with activity

TESTING/MONITORING REQUIREMENTS

The equipment to be used must be calibrated as per the manufacturers requirements, and bump tested at least daily before work commences. The worksite and surrounding areas noted above are to be tested at the following frequency.

Frequency (tick as applicable) Before the start of work Continuous monitoring during work After Fuel Delivery At a specified frequency

Acceptable levels of Gas/Vapour/Asphyxiant: Oxygen % Vol Max Min Flammables % of the LEL H2S ppm CO ppm Other (Specify)

Name/s of Authorised Gas Tester (AGT)

EQUIPMENT VALIDATION

Date	Make/Model	Gas Test Unit No.	Calibration Date	Bump Test Time	AGT signature

